

VOC Content Test Certificate

Thursday, 6th September 2012

Manufacturer: Construction Technologies Australia Pty Ltd (70 Platinum Street, Crestmead Queensland 4132)

Sample Description: ProGrip ceramic tile adhesive

Date Tested: June 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p>ProGrip</p>
Ceramic Tile Adhesive 65 grams per Litre	60 grams per Litre as VOC content per coating
<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p>ProGrip</p>
Ceramic Tile Adhesive 65 grams per Litre	60 grams per Litre as VOC content per coating



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0905-23